

CITY OF GOSHEN

FIRE PREVENTION INSPECTION CHECKLIST

The Fire Prevention Official will perform inspections of existing commercial establishments, including churches and other religious assembly structures on an annual basis.

Contact 479-841-0919 for your inspection. Building Safety is no Accident!

NAME _____ DATE _____ BUILDING _____

HOUSEKEEPING YES NO* N/A

- 1. Areas free of clutter and excessive combustible material? ___
- 2. Smoking areas clean, appropriate butt receptacle available? ___
- 3. Trash cans emptied, trash removed on a regular basis? ___

MEANS OF EGRESS

- 1. EXIT signs readily visible, illumination operable, battery OK? ___
- 2. Adequate lighting in corridors? ___
- 3. Exit doors not blocked, open easily, self closing? ___
- 4. Adequate corridor clearance - 44" minimum? ___
- 5. Emergency lighting operational during 30 second test? ___
- 6. Stairwells free of storage and doors kept closed? ___
- 7. No biological agents / radioactive materials / hazardous chemicals stored in corridors? ___

ELECTRICAL

- 1. Proper clearance (36" minimum width) in front of electrical panel boxes? ___
- 2. Extension cords not used in place of permanent wiring? ___
- 3. Power strips not used to supply electricity to heating devices or as an extension cord? ___
- 4. Portable space heaters approved for use, orange approval sticker visible, combustibles more than 36" away? ___

FIRE DETECTION / PROTECTION EQUIPMENT

- 1. Adequate clearance (18") for sprinkler heads? ___
- 2. Fire alarm pull stations visible and accessible? ___
- 3. Fire extinguishers visible, accessible, pin and seal in place, pressure OK, current year's tag, initial tag ___

* For items marked "NO" or other comments, describe below.

Comments/ Remedial Action

This document was created with Win2PDF available at <http://www.win2pdf.com>.
The unregistered version of Win2PDF is for evaluation or non-commercial use only.
This page will not be added after purchasing Win2PDF.